


**NOTES:**

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.
2. DRAWING NOT TO SCALE.
3. FINISH GRADE SHOULD BE GRADED SUCH TO PROMOTE DRAINAGE AWAY FROM THE FIELD.  
(SLOPE OF GRADE SHOULD BE GREATER THAN OR EQUAL TO 0.5%)
4. AGGREGATE BASE COURSE THICKNESS OVER THE EXCELDRAIN PRODUCT SHOULD BE 4 INCH MINIMUM (6 INCHES TYPICAL).

	AWD - AMERICAN WICK DRAIN CORPORATION 1209 AIRPORT ROAD MONROE, NC 28110 USA TOLL-FREE (US/CAN): +1 800-242-9425 PHONE: +1 704-238-9200 EMAIL: INFO@AWD-USA.COM WEBSITE: WWW.AWD-USA.COM	AWD 172	<b>ATHLETIC FIELD SUBBASE DRAINAGE - CROSS SECTION</b> SITEDRAIN STRIP PREFABRICATED GEOCOMPOSITE DRAINAGE SYSTEM	
		DRAWN/EDITED BY : SMM	PROJECT : TYPICAL DETAILS	REVISION DATE : 7/26/2023
		CHECKED/APRVD BY : SMM	SCALE : NTS	SHEET 1 OF 1