



SECTION A-A

NOTES:

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.
2. DRAWING NOT TO SCALE.
3. FINISH GRADE SHOULD BE GRADED SUCH TO PROMOTE DRAINAGE AWAY FROM THE FIELD.
(SLOPE OF GRADE SHOULD BE GREATER THAN OR EQUAL TO 0.5%)
4. SUBGRADE SHOULD BE GRADED SUCH TO PROMOTE DRAINAGE TOWARDS THE COLLECTION TRENCHES.
(SLOPE OF GRADE SHOULD BE GREATER THAN OR EQUAL TO 0.5%)
5. AGGREGATE BASE COURSE THICKNESS OVER THE EXCELDRAIN PRODUCT SHOULD BE 4 INCH MINIMUM (6 INCHES TYPICAL).



AWD - AMERICAN WICK DRAIN CORPORATION
 1209 AIRPORT ROAD
 MONROE, NC 28110 USA
 TOLL-FREE (US/CAN): +1 800-242-9425
 PHONE: +1 704-238-9200
 EMAIL: INFO@AWD-USA.COM
 WEBSITE: WWW.AWD-USA.COM



ATHLETIC FIELD SUBBASE DRAINAGE - EDGE DETAIL

SITEDRAIN STRIP PREFABRICATED GEOCOMPOSITE DRAINAGE SYSTEM

DRAWN/EDITED BY : SMM

PROJECT : TYPICAL DETAIL

REVISION DATE : 7/26/2023

CHECKED/APRVD BY : SMM

SCALE : NTS

SHEET 1 OF 1