


GENERAL NOTES

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.
2. DRAWING NOT TO SCALE.
3. FINISH GRADE SHOULD BE GRADED SUCH TO PROMOTE DRAINAGE AWAY FROM THE FIELD. (SLOPE OF GRADE SHOULD BE $\geq 0.5\%$)
4. SUBGRADE SHOULD BE GRADED SUCH TO PROMOTE DRAINAGE TOWARDS THE COLLECTION TRENCHES. (SLOPE OF GRADE SHOULD BE $\geq 0.5\%$)
5. AGGREGATE BASE COURSE THICKNESS OVER THE SITEDRAIN STRIP DRAIN PRODUCT SHOULD BE 4" MINIMUM (6" TYPICAL).



AWD - AMERICAN WICK DRAIN CORPORATION
 1209 AIRPORT ROAD
 MONROE, NC 28110 USA
 TOLL-FREE (US/CAN): +1 800-242-9425
 PHONE: +1 704-238-9200
 EMAIL: INFO@AWD-USA.COM
 WEBSITE: WWW.AWD-USA.COM



ATHLETIC FIELD SUB-BASE DRAINAGE - FLAT LAY - EDGE DETAIL (ISO)
 SITEDRAIN STRIP PREFABRICATED GEOCOMPOSITE DRAINAGE SYSTEM

DRAWN/EDITED BY : SMM	PROJECT : TYPICAL DETAILS	REVISION DATE : 7/26/2023
CHECKED/APRVD BY : SMM	SCALE : NTS	SHEET 1 OF 1